

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 1-May-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 30-Apr-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	30-Apr-20	0:00:00	30-Apr-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 01.05.2020), 1 SSP-CHPH M/cs are running at 10:00 hrs.
2	30-Apr-20	0:00:00	30-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	30-Apr-20	11:00:00	30-Apr-20	24:00:00	13:00:00	39.00	0.479	
4	30-Apr-20	0:00:00	30-Apr-20	0:00:00	0:00:00	0.00	0.000	
5	30-Apr-20	0:00:00	30-Apr-20	2:00:00	2:00:00	37.00	0.073	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	30-Apr-20	0:00:00	30-Apr-20	0:00:00	0:00:00	0	0.000	Today(i.e. 01.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	30-Apr-20	0:00	30-Apr-20	0:45	4:30:00	163	0.740	
		5:30		8:00				
3	30-Apr-20	22:45	30-Apr-20	24:00	5:30:00	165	0.904	
		0:00		1:00				
4	30-Apr-20	5:15	30-Apr-20	8:15	4:30:00	163	0.748	
		22:30		24:00				
5	30-Apr-20	5:45	30-Apr-20	8:30	3:00:00	163	0.498	
		22:15		24:00				
6	30-Apr-20	6:00:00	30-Apr-20	9:00:00	10:15:00	165	1.670	
		0:00		1:15				
		5:00		8:45				
		18:45		24:00				

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.552	4.560	5.112
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	48.721	135.250	183.971
PREVIOUS DAY ACTUAL RUNNING HOURS	15:00:00	27:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	27:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	29:15:00	

SSP hydrological data - at 08:00 Hrs on 1-May-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.89 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 10611 Cusec 26 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 12220 Cusec 30 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4173	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	4117	4540	7680	613



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRDC respectively. The details:

NIL