

**DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES**  
**(ENERGY MANAGEMENT CENTRE, INDORE)**

ISSUE DATE: 11-May-20  
 ISSUE TIME: 10:00 Hrs  
 FOR DATE: 10-May-20

Daily Plant Report  
(00:00 Hrs to 24:00Hrs.)

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-May-20	0:00:00	10-May-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 11.05.2020), 1 SSP-CHPH M/cs are running at 10:00 hrs.
2	10-May-20	0:00:00	10-May-20	0:00:00	0:00:00	0.00	0.000	
3	10-May-20	0:00:00	10-May-20	0:00:00	0:00:00	0.00	0.000	
4	10-May-20	0:00:00	10-May-20	0:00:00	0:00:00	0.00	0.000	
5	10-May-20	0:00:00	10-May-20	18:00:00	18:00:00	38.00	0.655	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-May-20	0:00:00	10-May-20	1:00:00	3:30:00	178	0.622	Today(i.e. 11.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	10-May-20	5:30:00	10-May-20	8:00:00	0:00:00	0	0.000	
3	10-May-20	0:00:00	10-May-20	0:00:00	0:00:00	0	0.000	
4	10-May-20	5:15:00	10-May-20	8:15:00	3:00:00	178	0.536	
5	10-May-20	5:45:00	10-May-20	8:30:00	2:45:00	178	0.490	
6	10-May-20	0:00:00	10-May-20	1:15:00	5:30:00	179	0.990	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)		0.655	2.638	3.293
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)		6.411	31.186	37.597
PREVIOUS DAY ACTUAL RUNNING HOURS		18:00:00	14:45:00	
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00	16:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	17:45:00	

SSP hydrological data : at 08:00 Hrs on 11-May-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 121.29 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 18300 Cusec 45 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 7277 Cusec 18 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3589	0

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	3036	2900	4377	655



Copy to :

**AEE (EMC)**  
**NCA, INDORE**

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

**1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.**

**2. SCO Mode Running Detail:**

**RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:**

**Nil**