

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 12-May-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 11-May-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	11-May-20	0:00:00	11-May-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 12.05.2020), 0 SSP-CHPH M/cs are running at 10:00 hrs.
2	11-May-20	0:00:00	11-May-20	0:00:00	0:00:00	0.00	0.000	
3	11-May-20	0:00:00	11-May-20	0:00:00	0:00:00	0.00	0.000	
4	11-May-20	0:00:00	11-May-20	0:00:00	0:00:00	0.00	0.000	
5	11-May-20	4:30:00	11-May-20	24:00:00	19:30:00	38.00	0.717	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	11-May-20	0:00:00	11-May-20	2:00:00	2:00:00	179	0.356	Today(i.e. 12.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	11-May-20	0:00:00	11-May-20	0:00:00	0:00:00	0	0.000	
3	11-May-20	6:15:00	11-May-20	8:15:00	2:00:00	179	0.356	
4	11-May-20	6:00:00	11-May-20	8:30:00	2:30:00	178	0.448	
5	11-May-20	5:45:00	11-May-20	8:45:00	3:00:00	177	0.540	
6	11-May-20	0:00:00 5:30 22:30	11-May-20	2:15 9:00 24:00	7:15:00	185	1.302	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		0.717	3.002	3.719
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		7.128	34.188	41.316
PREVIOUS DAY ACTUAL RUNNING HOURS		19:30:00	16:45:00	
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00	24:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	24:00:00	

SSP hydrological data : at 08:00 Hrs on 12-May-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.26 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 8895 Cusec 22 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 10459 Cusec 26 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3036	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	10459	3642	6817	657



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.4: 17:30 hrs on 11.05.2020 to 00:05 hrs on 12.05.2020

Unit No.5: 17:20 hrs on 11.05.2020 to 00:10 hrs on 12.05.2020