

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	12-May-20	0:00:00	12-May-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 12.05.2020), 1 SSP-CHPH M/cs are running at 10:00 hrs.
2	12-May-20	0:00:00	12-May-20	0:00:00	0:00:00	0.00	0.000	
3	12-May-20	0:00:00	12-May-20	0:00:00	0:00:00	0.00	0.000	
4	12-May-20	0:00:00	12-May-20	0:00:00	0:00:00	0.00	0.000	
5	12-May-20	0:00 15:00	12-May-20	1:00 24:00	10:00:00	38.00	0.370	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	12-May-20	6:00:00	12-May-20	8:45:00	2:45:00	183	0.506	Today(i.e. 12.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	12-May-20	6:15:00	12-May-20	8:30:00	2:15:00	183	0.416	
3	12-May-20	0:00:00	12-May-20	8:15:00	8:15:00	185	1.520	
4	12-May-20	0:00:00	12-May-20	0:00:00	0:00:00	0	0.000	
5	12-May-20	0:00:00	12-May-20	0:00:00	0:00:00	0	0.000	
6	12-May-20	0:00 22:00	12-May-20	9:15 24:00	11:15:00	186	2.070	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)		0.370	4.512	4.882
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		7.498	38.700	46.198
PREVIOUS DAY ACTUAL RUNNING HOURS		10:00:00	24:30:00	
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00	24:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	27:00:00	

SSP hydrological data : at 08:00 Hrs on 13-May-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.32 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 13884 Cusec 34 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 8784 Cusec 21 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3017	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	2038	2368	6416	657



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.4: 18:20 hrs on 12.05.2020 to 00:05 hrs on 13.05.2020

Unit No.5: 18:10 hrs on 12.05.2020 to 00:10 hrs on 13.05.2020

AEE (EMC)
NCA, INDORE