

Daily Plant Report  
(00:00 Hrs to 24:00Hrs.)

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	13-May-20	0:00:00	13-May-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 14.05.2020), 0 SSP-CHPH M/cs are running at 10:00 hrs.
2	13-May-20	0:00:00	13-May-20	0:00:00	0:00:00	0.00	0.000	
3	13-May-20	0:00:00	13-May-20	0:00:00	0:00:00	0.00	0.000	
4	13-May-20	11:00:00	13-May-20	24:00:00	13:00:00	38.00	0.484	
5	13-May-20	0:00:00	13-May-20	2:00:00	2:00:00	37.00	0.074	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	13-May-20	5:30:00	13-May-20	8:15:00	2:45:00	184	0.506	Today(i.e. 14.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	13-May-20	5:45:00	13-May-20	8:30:00	2:45:00	184	0.510	
3	13-May-20	0:00:22:15	13-May-20	2:45:24:00	4:30:00	184	0.828	
4	13-May-20	0:00:00	13-May-20	0:00:00	0:00:00	0	0.000	
5	13-May-20	6:00:00	13-May-20	8:45:00	2:45:00	184	0.510	
6	13-May-20	0:00:22:00	13-May-20	9:15:24:00	11:15:00	184	2.060	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		0.558	4.414	4.972
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		8.056	43.114	51.170
PREVIOUS DAY ACTUAL RUNNING HOURS		15:00:00	24:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00	27:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	26:00:00	

SSP hydrological data : at 08:00 Hrs on 14-May-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 121.38 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 15672 Cusec 38 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 10570 Cusec 26 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
2038	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	1968	2813	7757	659



Copy to :

AEE (EMC)  
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.4: 18:20 hrs on 13.05.2020 to 05:15 hrs on 14.05.2020

Unit No.5: 18:10 hrs on 13.05.2020 to 05:20 hrs on 14.05.2020