

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	14-May-20	0:00:00	14-May-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 15.05.2020), 0 SSP-CHPH M/cs are running at 10:00 hrs.
2	14-May-20	0:00:00	14-May-20	0:00:00	0:00:00	0.00	0.000	
3	14-May-20	0:00:00	14-May-20	0:00:00	0:00:00	0.00	0.000	
4	14-May-20	0:00:00	14-May-20	0:00:00	0:00:00	0.00	0.000	
5	14-May-20	16:00:00	14-May-20	24:00:00	8:00:00	38.00	0.298	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	14-May-20	5:30 22:15	14-May-20	8:30 24:00	4:45:00	185	0.870	Today(i.e. 15.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	14-May-20	0:00 5:45	14-May-20	3:00 9:00	6:15:00	184	1.148	
3	14-May-20	0:00 6:00	14-May-20	2:45 8:30	5:15:00	185	0.968	
4	14-May-20	0:00:00	14-May-20	0:00:00	0:00:00	0	0.000	
5	14-May-20	0:00:00	14-May-20	0:00:00	0:00:00	0	0.000	
6	14-May-20	0:00 22:00	14-May-20	8:45 24:45	10:45:00	185	1.974	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)		0.298	4.960	5.258
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)		8.354	48.074	56.428
PREVIOUS DAY ACTUAL RUNNING HOURS		8:00:00	27:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00	26:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	29:30:00	

SSP hydrological data : at 08:00 Hrs on 15-May-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.43 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 14244 Cusec 35 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 9881 Cusec 24 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
1968	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	2000	2746	7135	661



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL