

Daily Plant Report  
(00:00 Hrs to 24:00Hrs.)

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	15-May-20	0:00:00	15-May-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 16.05.2020), 0 SSP-CHPH M/cs are running at 10:00 hrs.
2	15-May-20	0:00:00	15-May-20	0:00:00	0:00:00	0.00	0.000	
3	15-May-20	0:00:00	15-May-20	0:00:00	0:00:00	0.00	0.000	
4	15-May-20	15:00:00	15-May-20	24:00:00	9:00:00	38.00	0.339	
5	15-May-20	0:00:00	15-May-20	4:45:00	4:45:00	37.00	0.171	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	15-May-20	0:00 5:30 17:45	15-May-20	2:45 8:00 24:00	11:30:00	185	2.104	Today(i.e. 16.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	15-May-20	0:00 5:45	15-May-20	3:00 8:15	5:30:00	185	1.016	
3	15-May-20	6:00:00	15-May-20	8:30:00	2:30:00	185	0.462	
4	15-May-20	0:00:00	15-May-20	0:00:00	0:00:00	0	0.000	
5	15-May-20	22:15:00	15-May-20	24:00:00	1:45:00	185	0.324	
6	15-May-20	0:00 5:15 17:30	15-May-20	3:15 8:45 24:00	13:15:00	185	2.438	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.510	6.344	6.854
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	8.864	54.418	63.282
PREVIOUS DAY ACTUAL RUNNING HOURS	13:45:00	34:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	33:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	34:30:00	

SSP hydrological data : at 08:00 Hrs on 16-May-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 121.34 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 10007 Cusec 24 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 16011 Cusec 39 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
2000	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	2761	3731	12280	660



Copy to :

AEE (EMC)  
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

**1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.**

**2. SCO Mode Running Detail:**

**RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:**

---