

Daily Plant Report
 (00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	16-May-20	0:00:00	16-May-20	0:00:00	0:00:00	0.00	0.000	Unit No. 3 Under L/C (AoH) from 9:30 Hrs dated 11.05.2020.
2	16-May-20	0:00:00	16-May-20	0:00:00	0:00:00	0.00	0.000	
3	16-May-20	0:00:00	16-May-20	0:00:00	0:00:00	0.00	0.000	
4	16-May-20	0:00:00	16-May-20	8:00:00	8:00:00	38.00	0.300	Today(i.e. 17.05.2020), 0 SSP-CHPH M/cs are running at 10:00 hrs.
5	16-May-20	17:00:00	16-May-20	24:00:00	7:00:00	37.00	0.258	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	16-May-20	0:00:00	16-May-20	8:00:00	8:00:00	185	1.464	Today(i.e. 17.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	16-May-20	6:00 23:30	16-May-20	8:15 24:00	2:45:00	185	0.478	
3	16-May-20	0:00:00	16-May-20	0:00:00	0:00:00	0	0.000	
4	16-May-20	21:45:00	16-May-20	24:00:00	2:15:00	185	0.420	
5	16-May-20	0:00 22:00	16-May-20	8:30 24:00	10:30:00	184	1.912	
6	16-May-20	0:00 22:15	16-May-20	8:45 24:00	10:30:00	184	1.918	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.558	6.192	6.750
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	9.422	60.610	70.032
PREVIOUS DAY ACTUAL RUNNING HOURS	15:00:00	34:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	34:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	32:15:00	

SSP hydrological data : at 08:00 Hrs on 17-May-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.31 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 10850 Cusec 27 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 12413 Cusec 30 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
2760	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	2725	3266	9147	658



Copy to :

AEE (EMC)
 NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL