

Daily Plant Report  
(00:00 Hrs to 24:00Hrs.)

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	17-May-20	0:00:00	17-May-20	0:00:00	0:00:00	0.00	0.000	Unit No. 3 Under L/C (AoH) from 9:30 Hrs dated 11.05.2020.
2	17-May-20	0:00:00	17-May-20	0:00:00	0:00:00	0.00	0.000	
3	17-May-20	0:00:00	17-May-20	0:00:00	0:00:00	0.00	0.000	
4	17-May-20	17:30:00	17-May-20	24:00:00	6:30:00	38.00	0.244	Today(i.e. 17.05.2020), 0 SSP-CHPH M/cs are running at 10:00 hrs.
5	17-May-20	0:00:00	17-May-20	8:30:00	8:30:00	38.00	0.312	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	17-May-20	21:30:00	17-May-20	24:00:00	2:30:00	184	0.454	Unit No. 6 under AoH from 18.05.2020  Today(i.e. 17.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	17-May-20	0:00:00	17-May-20	1:30:00	1:30:00	185	0.840	
3	17-May-20	6:00:00	17-May-20	9:00:00	3:00:00	184	0.552	
4	17-May-20	0:00:00	17-May-20	1:45:00	1:45:00	185	0.742	
5	17-May-20	0:00:00	17-May-20	8:15:00	8:15:00	184	1.870	
6	17-May-20	0:00:00	17-May-20	8:30:00	8:30:00	184	1.874	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		0.556	6.332	6.888
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		9.978	66.942	76.920
PREVIOUS DAY ACTUAL RUNNING HOURS		15:00:00	34:30:00	
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00	32:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	34:30:00	

SSP hydrological data : at 08:00 Hrs on 18-May-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 121.29 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 12128 Cusec 30 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 12951 Cusec 32 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec



HR	GODBOLE
2725	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	2719	3289	9662	658

Copy to :

AEE (EMC)  
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL