

Daily Plant Report
 (00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	18-May-20	0:00:00	18-May-20	0:00:00	0:00:00	0.00	0.000	Unit No. 3 Under L/C (AoH) from 9:30 Hrs dated 11.05.2020.
2	18-May-20	0:00:00	18-May-20	0:00:00	0:00:00	0.00	0.000	
3	18-May-20	0:00:00	18-May-20	0:00:00	0:00:00	0.00	0.000	
4	18-May-20	0:00:00	18-May-20	8:00:00	8:00:00	37.00	0.296	Today(i.e. 19.05.2020), 1 SSP-CHPH M/cs are running at 10:00 hrs.
5	18-May-20	17:15:00	18-May-20	24:00:00	6:45:00	37.00	0.243	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	18-May-20	0:00:00	18-May-20	3:00:00	5:00:00	186	0.922	Unit No. 6 under AoH from 9:30 Hrs dated 18.05.2020 Today(i.e. 19.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
		22:00:00		24:00:00				
2	18-May-20	6:00:00	18-May-20	9:00:00	5:15:00	185	0.972	
		21:45:00		24:00:00				
3	18-May-20	22:15:00	18-May-20	24:00:00	1:45:00	188	0.330	
		0:00:00		3:15:00				
4	18-May-20	5:30:00	18-May-20	8:45:00	6:30:00	183	1.194	
		0:00:00		1:15:00				
5	18-May-20	5:45:00	18-May-20	8:30:00	5:30:00	186	1.016	
		22:30:00		24:00:00				
6	18-May-20	0:00:00	18-May-20	8:15:00	8:15:00	185	1.522	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN (MUs)	0.539	5.956	6.495
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	10.517	72.898	83.415
PREVIOUS DAY ACTUAL RUNNING HOURS	14:45:00	32:15:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	34:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	28:15:00	

SSP hydrological data : at 08:00 Hrs on 19-May-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.30 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 14852 Cusec 36 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 13454 Cusec 33 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec



HR	GODBOLE
2718	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	3521	3179	10275	657

Copy to :

AEE (EMC)
 NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL