

Daily Plant Report  
(00:00 Hrs to 24:00Hrs.)

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	1-May-20	0:00:00	1-May-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 02.05.2020), 0 SSP-CHPH M/cs are running at 10:00 hrs.
2	1-May-20	0:00:00	1-May-20	0:00:00	0:00:00	0.00	0.000	
3	1-May-20	0:00:00	1-May-20	24:00:00	24:00:00	36.00	0.856	
4	1-May-20	0:00:00	1-May-20	0:00:00	0:00:00	0.00	0.000	
5	1-May-20	0:00:00	1-May-20	0:00:00	0:00:00	0.00	0.000	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	1-May-20	5:45:00	1-May-20	8:15:00	2:30:00	165	0.416	Today(i.e. 02.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	1-May-20	0:00	1-May-20	2:00	4:30:00	164	0.740	
3	1-May-20	0:00	1-May-20	1:45	3:30:00	164	0.574	
4	1-May-20	0:00	1-May-20	1:30	3:30:00	164	0.570	
5	1-May-20	22:00	1-May-20	24:00	24:00:00	163	0.248	
6	1-May-20	22:30:00	1-May-20	24:00	7:45	11:45:00	166	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		0.856	4.472	5.328
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		0.856	4.472	5.328
PREVIOUS DAY ACTUAL RUNNING HOURS		24:00:00	27:15:00	
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00	29:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	20:00:00	

SSP hydrological data : at 08:00 Hrs on 2-May-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 120.85 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 11011 Cusec 27 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 13329 Cusec 33 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
4116	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	4163	5197	8132	644



Copy to :

AEE (EMC)  
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL