

Daily Plant Report  
(00:00 Hrs to 24:00Hrs.)

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	19-May-20	0:00:00	19-May-20	0:00:00	0:00:00	0.00	0.000	Unit No. 3 Under L/C (AoH) from 9:30 Hrs dated 11.05.2020.
2	19-May-20	0:00:00	19-May-20	0:00:00	0:00:00	0.00	0.000	
3	19-May-20	0:00:00	19-May-20	0:00:00	0:00:00	0.00	0.000	
4	19-May-20	17:00:00	19-May-20	24:00:00	7:00:00	38.00	0.267	Today(i.e. 20.05.2020), 0 SSP-CHPH M/cs are running at 10:00 hrs.
5	19-May-20	0:00:00	19-May-20	11:00:00	11:00:00	39.00	0.402	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	19-May-20	0:00:00	19-May-20	1:15:00	3:15:00	185	0.594	Unit No. 6 under AoH from 9:30 Hrs dated 18.05.2020 Today(i.e. 20.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
		22:00:00		24:00:00				
2	19-May-20	0:00:00	19-May-20	3:15:00	9:00:00	185	1.644	
		5:15:00		9:15:00				
3	19-May-20	0:00:00	19-May-20	3:00:00	7:15:00	186	1.332	
		22:15:00		24:00:00				
4	19-May-20	4:45:00	19-May-20	9:00:00	4:15:00	186	0.790	
		5:00:00		9:15:00				
5	19-May-20	0:00:00	19-May-20	8:45:00	10:45:00	186	1.982	
		22:00:00		24:00:00				
6	19-May-20	0:00:00	19-May-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.669	6.342	7.011
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	11.186	79.240	90.426
PREVIOUS DAY ACTUAL RUNNING HOURS	18:00:00	34:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	32:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	30:00:00	

SSP hydrological data : at 08:00 Hrs on 20-May-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 121.33 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 17090 Cusec 42 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 14211 Cusec 35 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3521	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	4222	3931	10280	658



Copy to :

AEE (EMC)  
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

**1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.**

**2. SCO Mode Running Detail:**

**RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:**

**NIL**