

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 21-May-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 20-May-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	20-May-20	0:00:00	20-May-20	0:00:00	0:00:00	0.00	0.000	Unit No. 3 Under L/C (AoH) from 9:30 Hrs dated 11.05.2020.
2	20-May-20	0:00:00	20-May-20	0:00:00	0:00:00	0.00	0.000	
3	20-May-20	0:00:00	20-May-20	0:00:00	0:00:00	0.00	0.000	
4	20-May-20	0:00:00	20-May-20	24:00:00	24:00:00	38.00	0.891	Today(i.e. 21.05.2020), 1 SSP-CHPH M/cs are running at 10:00 hrs.
5	20-May-20	0:00:00	20-May-20	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	20-May-20	0:00:00	20-May-20	8:15:00	10:15:00	185	1.866	Unit No. 6 under AoH from 9:30 Hrs dated 18.05.2020
2	20-May-20	0:00:00	20-May-20	8:15:00	10:00:00	184	1.830	
3	20-May-20	6:00:00	20-May-20	8:30:00	2:30:00	184	0.462	
4	20-May-20	0:00:00	20-May-20	0:00:00	0:00:00	0	0.000	
5	20-May-20	0:00:00	20-May-20	8:00:00	9:30:00	184	1.742	Today(i.e. 21.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
6	20-May-20	0:00:00	20-May-20	0:00:00	0:00:00	0	0.000	

GROSS GENERATION IN(MUs)		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
		0.891	5.900	6.791
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		12.077	85.140	97.217
PREVIOUS DAY ACTUAL RUNNING HOURS		24:00:00	32:15:00	
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00	34:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	34:00:00	

SSP hydrological data : at 08:00 Hrs on 21-May-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.28 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 10776 Cusec 26 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 13821 Cusec 34 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4222	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	4718	5198	8623	658



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL