

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	21-May-20	0:00:00	21-May-20	0:00:00	0:00:00	0.00	0.000	Unit No. 3 Under L/C (AoH) from 9:30 Hrs dated 11.05.2020.
2	21-May-20	0:00:00	21-May-20	0:00:00	0:00:00	0.00	0.000	
3	21-May-20	0:00:00	21-May-20	0:00:00	0:00:00	0.00	0.000	
4	21-May-20	0:00:00	21-May-20	24:00:00	24:00:00	38.00	0.886	Today(i.e. 22.05.2020), 1 SSP-CHPH M/cs are running at 10:00 hrs.
5	21-May-20	0:00:00	21-May-20	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	21-May-20	0:00:00	21-May-20	8:15:00	10:00:00	185	1.820	Unit No. 6 under AoH from 9:30 Hrs dated 18.05.2020
2	21-May-20	0:00:00	21-May-20	8:30:00	9:30:00	184	1.726	
3	21-May-20	22:45:00	21-May-20	24:00:00	1:15:00	184	0.222	
4	21-May-20	22:30:00	21-May-20	24:00:00	1:30:00	184	0.278	
5	21-May-20	0:00:00	21-May-20	8:45:00	14:00:00	185	2.574	
6	21-May-20	0:00:00	21-May-20	0:00:00	0:00:00	0	0.000	

CHPH (5 X 50MW)		RBPH (6X200 MW)		SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.886	6.620	7.506	
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	12.963	91.760	104.723	
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	36:15:00		
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	34:00:00		
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	18:15:00		

SSP hydrological data : at 08:00 Hrs on 22-May-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.25 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 13933 Cusec 34 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 15499 Cusec 38 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
4717	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	5261	5252	10247	656



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL