

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 23-May-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 22-May-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

Date: 23-May-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	22-May-20	0:00:00	22-May-20	0:00:00	0:00:00	0.00	0.000	Unit No. 3 Under L/C (AoH) from 9:30 Hrs dated 11.05.2020.
2	22-May-20	0:00:00	22-May-20	0:00:00	0:00:00	0.00	0.000	
3	22-May-20	0:00:00	22-May-20	0:00:00	0:00:00	0.00	0.000	
4	22-May-20	0:00:00	22-May-20	24:00:00	24:00:00	38.00	0.890	Today(i.e. 23.05.2020), 1 SSP-CHPH M/cs are running at 10:00 hrs.
5	22-May-20	0:00:00	22-May-20	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	22-May-20	0:00 21:45	22-May-20	2:00 24:00	4:15:00	184	0.768	Unit No. 6 under AoH from 9:30 Hrs dated 18.05.2020 Today(i.e. 23.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	22-May-20	0:00 22:00	22-May-20	1:45 24:00	3:45:00	184	0.682	
3	22-May-20	0:00 5:30 22:15	22-May-20	1:30 9:30 24:00	7:15:00	183	1.334	
4	22-May-20	0:00:00	22-May-20	8:30:00	8:30:00	184	1.564	
5	22-May-20	0:00:00	22-May-20	7:30:00	7:30:00	183	1.354	
6	22-May-20	0:00:00	22-May-20	0:00:00	0:00:00	0	0.000	

CHPH (5 X 50MW)		RBPH (6X200 MW)		SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)		0.890		5.702
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)		13.853		97.462
PREVIOUS DAY ACTUAL RUNNING HOURS		24:00:00		31:15:00
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00		18:15:00
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00		24:00:00

SSP hydrological data : at 08:00 Hrs on 23-May-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.24 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 11330 Cusec 28 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 11415 Cusec 28 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
4800	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	5288	5255	6160	656



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL