

**DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES**  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 24-May-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 23-May-20

Daily Plant Report  
(00:00 Hrs to 24:00Hrs.)

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	23-May-20	0:00:00	23-May-20	0:00:00	0:00:00	0.00	0.000	Unit No. 3 Under L/C (AoH) from 9:30 Hrs dated 11.05.2020.
2	23-May-20	0:00:00	23-May-20	0:00:00	0:00:00	0.00	0.000	
3	23-May-20	0:00:00	23-May-20	0:00:00	0:00:00	0.00	0.000	
4	23-May-20	0:00:00	23-May-20	11:00:00	11:00:00	37.00	0.401	Today(i.e. 24.05.2020), 1 SSP-CHPH M/cs are running at 10:00 hrs.
5	23-May-20	15:00:00	23-May-20	24:00:00	9:00:00	38.00	0.330	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	23-May-20	0:00 5:15 22:45	23-May-20	1:15 7:45 24:00	5:00:00	185	0.932	Unit No. 6 under AoH from 9:30 Hrs dated 18.05.2020
2	23-May-20	0:00 5:30	23-May-20	1:30 8:00	4:00:00	183	0.744	
3	23-May-20	0:00 5:45	23-May-20	3:15 8:15	5:45:00	185	1.068	
4	23-May-20	22:00:00	23-May-20	24:00:00	2:00:00	184	0.372	Today(i.e. 24.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
5	23-May-20	22:30:00	23-May-20	24:00:00	1:30:00	184	0.278	
6	23-May-20	0:00:00	23-May-20	0:00:00	0:00:00	0	0.000	

CHPH (5 X 50MW)		RBPH (6X200 MW)		SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)		0.731		4.125
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)		14.584		115.440
PREVIOUS DAY ACTUAL RUNNING HOURS		20:00:00		18:15:00
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00		20:30:00
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00		22:45:00

SSP hydrological data : at 08:00 Hrs on 24-May-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 121.21 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 7912 Cusec 19 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 9478 Cusec 23 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
5200	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	5648	4342	5136	655



Copy to :

AEE (EMC)  
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL