

Daily Plant Report  
 (00:00 Hrs to 24:00Hrs)

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	25-May-20	0:00:00	25-May-20	0:00:00	0:00:00	0.00	0.000	CHPH M/cs are running at 10:00 hrs.
2	25-May-20	0:00:00	25-May-20	0:00:00	0:00:00	0.00	0.000	
3	25-May-20	16:55:00	25-May-20	24:00:00	7:05:00	37.00	0.263	
4	25-May-20	0:00:00	25-May-20	17:00:00	17:00:00	37.00	0.633	
5	25-May-20	0:00:00	25-May-20	1:00:00	1:00:00	37.00	0.034	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	25-May-20	0:00:00 5:45 22:15	25-May-20	2:30 9:00 24:00	7:30:00	186	1.382	Unit No. 6 under AoH from 9:30 Hrs dated 18.05.2020  Today (i.e. 26.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	25-May-20	6:15:00	25-May-20	8:45:00	2:30:00	183	0.462	
3	25-May-20	0:00:00	25-May-20	0:00:00	0:00:00	0	0.000	
4	25-May-20	0:00:00 6:00 21:45	25-May-20	2:15 8:30 24:00	7:00:00	184	1.300	
5	25-May-20	0:00:00 5:30 22:00	25-May-20	1:00:00 8:15 24:00	5:45:00	184	1.066	
6	25-May-20	0:00:00	25-May-20	0:00:00	0:00:00	0	0.000	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN (MUS)		0.930	4.210	5.140
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)		16.661	108.882	125.543
PREVIOUS DAY ACTUAL RUNNING HOURS		25:05:00	22:45:00	
TODAY'S DC (Schedule) Planned (in Hours)		48:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	16:45:00	

SSP hydrological data: at 08:00 Hrs on 26-May-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 121.34 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 15654 Cusec 38 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 7591 Cusec 19 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
5800	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	6037	5243	2348	657



Copy to :

AEE (EMC)  
 NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.2: 18:00 hrs on 25.05.2020 to 6:00 hrs on 26.05.2020

Unit No.3: 18:15 hrs on 25.05.2020 to 5:55 hrs on 26.05.2020