

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 3-May-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 2-May-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	2-May-20	0:00:00	2-May-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 03.05.2020), 1 SSP-CHPH M/cs are running at 10:00 hrs.
2	2-May-20	0:00:00	2-May-20	0:00:00	0:00:00	0.00	0.000	
3	2-May-20	0:00:00	2-May-20	9:15:00	9:15:00	36.00	0.325	
4	2-May-20	0:00:00	2-May-20	0:00:00	0:00:00	0.00	0.000	
5	2-May-20	17:00:00	2-May-20	24:00:00	7:00:00	38.00	0.254	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	2-May-20	22:00:00	2-May-20	24:00:00	2:00:00	169	0.326	Today(i.e. 03.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	2-May-20	0:00:00	2-May-20	0:00:00	0:00:00	0	0.000	
3	2-May-20	0:00:54:5	2-May-20	1:45:8:15	4:15:00	168	0.710	
4	2-May-20	0:00:22:15	2-May-20	8:00:24:00	9:45:00	169	1.652	
5	2-May-20	0:00:00	2-May-20	1:30:00	1:30:00	167	0.254	
6	2-May-20	0:00:20:00	2-May-20	7:45:24:00	11:45:00	170	1.980	

GROSS GENERATION IN(MUS)		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
		0.579	4.922	5.501
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)		1.435	9.394	10.829
PREVIOUS DAY ACTUAL RUNNING HOURS		16:15:00	29:15:00	
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00	20:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	20:15:00	

SSP hydrological data : at 08:00 Hrs on 3-May-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.82 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 8017 Cusec 20 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 9595 Cusec 23 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4162	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	4124	3523	6072	643



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Nil