

**DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES**  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 4-May-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 3-May-20

Daily Plant Report  
(00:00 Hrs to 24:00Hrs.)

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	3-May-20	0:00:00	3-May-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 04.05.2020), 1 SSP-CHPH M/cs are running at 10:00 hrs.
2	3-May-20	0:00:00	3-May-20	0:00:00	0:00:00	0.00	0.000	
3	3-May-20	0:00:00	3-May-20	0:00:00	0:00:00	0.00	0.000	
4	3-May-20	0:00:00	3-May-20	0:00:00	0:00:00	0.00	0.000	
5	3-May-20	0:00:00	3-May-20	24:00:00	24:00:00	36.00	0.856	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	3-May-20	0:00 22:00	3-May-20	0:45 24:00	2:45:00	169	0.464	Today(i.e. 04.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	3-May-20	0:00:00	3-May-20	0:00:00	0:00:00	0	0.000	
3	3-May-20	6:00:00	3-May-20	8:15:00	2:15:00	168	0.378	
4	3-May-20	0:00 22:30	3-May-20	3:45 24:00	5:15:00	169	0.896	
5	3-May-20	0:00:00	3-May-20	0:00:00	0:00:00	0	0.000	
6	3-May-20	0:00 22:15	3-May-20	8:00 24:00	9:45:00	169	1.632	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)		0.856	3.370	4.226
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)		2.291	12.764	15.055
PREVIOUS DAY ACTUAL RUNNING HOURS		24:00:00	20:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00	20:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	17:00:00	

SSP hydrological data : at 08:00 Hrs on 4-May-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 120.77 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 5882 Cusec 14 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 8944 Cusec 22 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4124	0

• AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	4118	3667	5277	642



Copy to :

AEE (EMC)  
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details: