

Daily Plant Report  
(00:00 Hrs to 24:00Hrs.)

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	4-May-20	0:00:00	4-May-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 05.05.2020), 1 SSP-CHPH M/cs are running at 10:00 hrs.
2	4-May-20	0:00:00	4-May-20	0:00:00	0:00:00	0.00	0.000	
3	4-May-20	0:00:00	4-May-20	0:00:00	0:00:00	0.00	0.000	
4	4-May-20	0:00:00	4-May-20	0:00:00	0:00:00	0.00	0.000	
5	4-May-20	0:00:00 9:00	4-May-20	1:00:00 24:00	16:00:00	38.00	0.572	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	4-May-20	0:00:00 22:15	4-May-20	3:45:00 24:00	5:30:00	168	0.916	Today(i.e. 05.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	4-May-20	22:30:00	4-May-20	24:00:00	1:30:00	168	0.254	
3	4-May-20	0:00:00	4-May-20	0:00:00	0:00:00	0	0.000	
4	4-May-20	0:00:00 5:45	4-May-20	0:45:00 8:15	3:15:00	169	0.560	
5	4-May-20	0:00:00	4-May-20	0:00:00	0:00:00	0	0.000	
6	4-May-20	0:00:00 22:00	4-May-20	8:00:00 24:00	10:00:00	170	1.686	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.572	3.416	3.988
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	2.863	16.180	19.043
PREVIOUS DAY ACTUAL RUNNING HOURS	16:00:00	20:15:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	7:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	7:15:00	

SSP hydrological data : at 08:00 Hrs on 5-May-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 120.77 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 10546 Cusec 26 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 9905 Cusec 24 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
4117	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	4090	4950	4955	641



Copy to :

AEE (EMC)  
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

///