

Daily Plant Report  
(00:00 Hrs to 24:00Hrs.)

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	6-May-20	0:00:00	6-May-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 07.05.2020), 1 SSP-CHPH M/cs are running at 10:00 hrs.
2	6-May-20	0:00:00	6-May-20	0:00:00	0:00:00	0.00	0.000	
3	6-May-20	0:00:00	6-May-20	10:00:00	10:00:00	36.00	0.360	
4	6-May-20	0:00:00	6-May-20	0:00:00	0:00:00	0.00	0.000	
5	6-May-20	17:00:00	6-May-20	24:00:00	7:00:00	38.00	0.259	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	6-May-20	0:00:00	6-May-20	0:00:00	0:00:00	0	0.000	Today(i.e. 07.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	6-May-20	6:00:00	6-May-20	8:00:00	2:00:00	168	0.338	
3	6-May-20	0:00:00	6-May-20	0:00:00	0:00:00	0	0.000	
4	6-May-20	0:00:00	6-May-20	0:00:00	0:00:00	0	0.000	
5	6-May-20	0:00:00	6-May-20	0:00:00	0:00:00	0	0.000	
6	6-May-20	0:00:54	6-May-20	2:45:15	5:15:00	169	0.890	

CHPH (5 X 50MW)		RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.619	1.228	1.847
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	4.048	20.154	24.202
PREVIOUS DAY ACTUAL RUNNING HOURS	17:00:00	7:15:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	11:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	10:00:00	

SSP hydrological data : at 08:00 Hrs on 7-May-20

**DATA RECEIVED FROM FLOOD CELL.**

- RESERVOIR LEVEL IN Metres 121.03 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 24003 Cusec 59 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 6326 Cusec 15 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec



HR	GODBOLE
3580	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	3575	3714	2612	645

Copy to :

AEE (EMC)  
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.1: 20:15 hrs on 06.05.2020 to 00:05 hrs on 07.05.2020

Unit No.3: 20:25 hrs on 06.05.2020 to 05:50 hrs on 07.05.2020