

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 8-May-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 7-May-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	7-May-20	0:00:00	7-May-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 08.05.2020), 1 SSP-CHPH M/cs are running at 10:00 hrs.
2	7-May-20	0:00:00	7-May-20	0:00:00	0:00:00	0.00	0.000	
3	7-May-20	0:00:00	7-May-20	0:00:00	0:00:00	0.00	0.000	
4	7-May-20	0:00:00	7-May-20	0:00:00	0:00:00	0.00	0.000	
5	7-May-20	0:00:00	7-May-20	17:30:00	17:30:00	37.00	0.634	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	7-May-20	5:45:00	7-May-20	8:00:00	2:15:00	174	0.388	Today(i.e. 08.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	7-May-20	0:15:30	7-May-20	3:15:00	5:45:00	173	0.980	
3	7-May-20	23:15:00	7-May-20	24:00:00	0:45:00	175	0.136	
4	7-May-20	0:00:23:00	7-May-20	2:15:24:00	3:15:00	175	0.570	
5	7-May-20	0:00:00	7-May-20	0:00:00	0:00:00	0	0.000	
6	7-May-20	0:00:00	7-May-20	0:00:00	0:00:00	0	0.000	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		0.634	2.074	2.708
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		4.682	22.228	26.910
PREVIOUS DAY ACTUAL RUNNING HOURS		17:30:00	12:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00	14:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	25:15:00	

SSP hydrological data : at 08:00 Hrs on 8-May-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.03 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6784 Cusec 17 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 6135 Cusec 15 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3575	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	2975	2019	4116	649



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL