

**DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES**  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 9-May-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 8-May-20

Daily Plant Report  
(00:00 Hrs to 24:00Hrs.)

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	8-May-20	0:00:00	8-May-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 09.05.2020), 0 SSP-CHPH M/cs are running at 10:00 hrs.
2	8-May-20	0:00:00	8-May-20	0:00:00	0:00:00	0.00	0.000	
3	8-May-20	8:00:00	8-May-20	11:20:00	3:20:00	37.00	0.122	
4	8-May-20	11:15:00	8-May-20	24:00:00	12:45:00	38.00	0.472	
5	8-May-20	0:00:00	8-May-20	0:00:00	0:00:00	0.00	0.000	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	8-May-20	0:00:00	8-May-20	0:00:00	0:00:00	0	0.000	Today(i.e. 09.05.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	8-May-20	0:00:00	8-May-20	0:00:00	0:00:00	0	0.000	
3	8-May-20	0:00:00	8-May-20	8:30:00	8:30:00	179	1.510	
4	8-May-20	0:00:00	8-May-20	2:30:00	5:30:00	179	0.996	
5	8-May-20	0:00:00	8-May-20	0:00:00	0:00:00	0	0.000	
6	8-May-20	0:00:00	8-May-20	0:00:00	0:00:00	0	0.000	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		0.594	2.506	3.100
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		5.276	24.734	30.010
PREVIOUS DAY ACTUAL RUNNING HOURS		16:05:00	14:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00	21:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	14:45:00	

SSP hydrological data : at 08:00 Hrs on 9-May-20

**DATA RECEIVED FROM FLOOD CELL.**

- RESERVOIR LEVEL IN Metres 121.16 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 18132 Cusec 44 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 7854 Cusec 19 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
2975	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	2610	3468	4386	651



Copy to :

AEE (EMC)  
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit 2: Start at 17:55 on date 8.05.2020 and stopped at 6:10 on date 9.05.2020.

Unit 3: Start at 18:05 on date 8.05.2020 and stopped at 6:15 on date 9.05.2020.