



**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-May-21	0:00:00	10-May-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 11.05.2021), 2 SSP-CHPH M/cs are running at 10:00 hrs.  SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	10-May-21	0:00:00	10-May-21	0:00:00	0:00:00	0.00	0.000	
3	10-May-21	0:00:00	10-May-21	24:00:00	24:00:00	42.00	0.989	
4	10-May-21	0:00:00	10-May-21	24:00:00	24:00:00	41.00	0.987	
5	10-May-21	0:00:00	10-May-21	0:00:00	0:00:00	0.00	0.000	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-May-21	5:00:00	10-May-21	9:00:00	4:00:00	200	0.796	Today (i.e. 11.05.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	10-May-21	5:15:00	10-May-21	9:15:00	4:00:00	200	0.798	
3	10-May-21	0:00:00	10-May-21	0:00:00	0:00:00	0	0.000	
4	10-May-21	5:30:00	10-May-21	9:30:00	4:00:00	200	0.800	
5	10-May-21	21:30:00	10-May-21	24:00:00	2:30:00	199	0.502	
6	10-May-21	0:00:00	10-May-21	1:15:00	1:15:00	199	0.250	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.976	3.146	5.122
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	18.879	40.560	59.439
PREVIOUS DAY ACTUAL RUNNING HOURS	48:00:00	15:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	15:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	21:00:00	

SSP hydrological data : at 08:00 Hrs on 11-May-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 123.55 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 30494 Cusec 74.61 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 14218 Cusec 34.79 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
9474	620

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	9620	9436	4782	725



Rajesh Sharma  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG. CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor,Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.1: 20:50 Hrs on 10.05.2021 to 04:35 Hrs on 11.05.2021.

Unit No.2: 21:00 Hrs on 10.05.2021 to 04:40 Hrs on 11.05.2021.