

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	25-May-21	0:00:00	25-May-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 26.05.2021), 1 SSP-CHPH M/cs are running at 10:00 hrs. SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	25-May-21	0:00:00	25-May-21	0:00:00	0:00:00	0.00	0.000	
3	25-May-21	0:00:00	25-May-21	0:00:00	0:00:00	0.00	0.000	
4	25-May-21	0:00:00	25-May-21	24:00:00	24:00:00	46.00	1.053	
5	25-May-21	0:00:12:00	25-May-21	04:30:24:00	16:30:00	43.00	0.688	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	25-May-21	5:30:00	25-May-21	8:30:00	3:00:00	199	0.600	Today (i.e. 26.05.2021), No SSP-RBPH M/c is running at 10:00 hrs.
2	25-May-21	5:45:00	25-May-21	10:45:00	5:00:00	200	1.000	
3	25-May-21	0:00:00	25-May-21	0:00:00	0:00:00	0	0.000	
4	25-May-21	0:00:00	25-May-21	0:00:00	0:00:00	0	0.000	
5	25-May-21	5:00:21:15	25-May-21	11:00:24:00	8:45:00	200	1.750	
6	25-May-21	5:15:21:30	25-May-21	11:15:24:00	8:30:00	200	1.684	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		1.741	5.034	6.775
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		40.027	111.654	151.681
PREVIOUS DAY ACTUAL RUNNING HOURS		40:30:00	25:15:00	
TODAY'S DC (Schedule) Planned (in Hours)		39:30:00	55:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		48:00:00	58:15:00	

SSP hydrological data : at 08:00 Hrs on 26-May-21

DATA RECEIVED FROM FLOOD CELL

· RESERVOIR LEVEL IN Metres	124.96 Mtrs.	
· AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs).	16864 Cusec	41.26 MCM
· AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs).	18313 Cusec	44.80 MCM
· GOG WATER REQUIREMENT (Next Day) in Cusec		

HR	GODBOLE
8435	0

· AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	9255	8364	9949	772



Rajesh Sharma
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG. CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1,Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Detail:-