


नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY
DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 28-May-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 27-May-21

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

Date: 28-May-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	27-May-21	0:00:00	27-May-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 28.05.2021), 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	27-May-21	0:00:00	27-May-21	0:00:00	0:00:00	0.00	0.000	
3	27-May-21	0:00:00	27-May-21	0:00:00	0:00:00	0.00	0.000	
4	27-May-21	0:00:00	27-May-21	24:00:00	24:00:00	45.00	1.043	
5	27-May-21	0:00 10:30	27-May-21	02:00 24:00	15:30:00	43.00	0.648	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	27-May-21	0:00 13:15 19:15	27-May-21	1:30 16:45 24:00	9:45:00	201	1.942	Today (i.e. 28.05.2021), No SSP-RBPH M/c is running at 10:00 hrs.
2	27-May-21	0:00 5:15 13:30 20:00	27-May-21	2:00 8:45 17:00 24:00	13:00:00	200	2.590	
3	27-May-21	21:30:00	27-May-21	24:00:00	2:30:00	200	0.502	
4	27-May-21	0:00:00	27-May-21	0:00:00	0:00:00	0	0.000	
5	27-May-21	0:00 19:00	27-May-21	8:30 24:00	13:30:00	199	2.702	
6	27-May-21	0:00 13:45	27-May-21	8:15 24:00	18:30:00	200	3.674	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.691	11.410	13.101
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	43.411	132.936	176.347
PREVIOUS DAY ACTUAL RUNNING HOURS	39:30:00	57:15:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	57:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	57:15:00	

SSP hydrological data : at 08:00 Hrs on 28-May-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 124.66 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 18031 Cusec 44.11 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 25412 Cusec 62.17 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
9186	0

· AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	9226	8697	16715	764



Rajesh Sharma
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Detail:- NIL