

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 9-May-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 8-May-21

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	8-May-21	0:00:00	8-May-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 09.05.2021), 1 SSP-CHPH M/c are running at 10:00 hrs.
2	8-May-21	0:00:00	8-May-21	0:00:00	0:00:00	0.00	0.000	
3	8-May-21	0:00:00	8-May-21	24:00:00	24:00:00	41.00	0.981	
4	8-May-21	0:00:00	8-May-21	24:00:00	24:00:00	42.00	0.993	
5	8-May-21	0:00:00	8-May-21	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	8-May-21	5:15:00	8-May-21	8:45:00	3:30:00	200	0.698	Today (i.e. 09..05.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	8-May-21	5:30 21:30	8-May-21	9:15 24:00	6:15:00	204	1.262	
3	8-May-21	0:00:00	8-May-21	0:00:00	0:00:00	0	0.000	
4	8-May-21	5:45:00	8-May-21	9:45:00	4:00:00	204	0.810	
5	8-May-21	5:00:00	8-May-21	8:30:00	3:30:00	205	0.692	
6	8-May-21	6:00:00	8-May-21	9:00:00	3:00:00	204	0.608	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		1.974	4.070	6.044
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		15.240	33.352	48.592
PREVIOUS DAY ACTUAL RUNNING HOURS		48:00:00	20:15:00	
TODAY'S DC (Schedule) Planned (in Hours)		48:00:00	20:45:00	
DAY AHEAD (TOMMOROW) DC (in Hours)		48:00:00	21:15:00	

SSP hydrological data : at 08:00 Hrs on 9-May-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 123.30 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 24648 Cusec 60.30 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 16524 Cusec 40.43 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
9544	621

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
615	0	9513	10676	5848	718



Rajesh Sharma
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor,Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

SCO Mode Detail:

Unit No. 4: 19:45 hrs on 08.05.2021 to 04:35 hrs on 09.05.2021.

Unit No. 5: 19:55 hrs on 08.05.2021 to 04:40 hrs on 09.05.2021.