



(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|-----------|----------|-----------|----------|-------------|----------------|-------------------|--|
| 1 | 12-Nov-18 | 8:15:00 | 12-Nov-18 | 24:00:00 | 15:45:00 | 49.00 | 0.753 | Today(i.e. 13.11.18), 3 CHPH M/cs is running at 10:00 hrs. |
| 2 | 12-Nov-18 | 0:00:00 | 12-Nov-18 | 8:30:00 | 8:30:00 | 50.00 | 0.406 | |
| 3 | 12-Nov-18 | 10:40:00 | 12-Nov-18 | 24:00:00 | 13:20:00 | 50.00 | 0.641 | |
| 4 | 12-Nov-18 | 0:00:00 | 12-Nov-18 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 5 | 12-Nov-18 | 0:00:00 | 12-Nov-18 | 24:00:00 | 24:00:00 | 50.00 | 1.133 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|-----------|---------|-----------|---------|-------------|----------------|-------------------|---|
| 1 | 12-Nov-18 | 0:00:00 | 12-Nov-18 | 0:00:00 | 0:00:00 | 0 | 0.000 | Today(i.e. 13.11.18), no SSP-RBPH M/c is scheduled. |
| 2 | 12-Nov-18 | 0:00:00 | 12-Nov-18 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 3 | 12-Nov-18 | 0:00:00 | 12-Nov-18 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 4 | 12-Nov-18 | 0:00:00 | 12-Nov-18 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 5 | 12-Nov-18 | 0:00:00 | 12-Nov-18 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 6 | 12-Nov-18 | 0:00:00 | 12-Nov-18 | 0:00:00 | 0:00:00 | 0 | 0.000 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs) | 2.933 | 0.000 | 2.933 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs) | 16.529 | 0.000 | 16.529 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 61:35:00 | 0:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 24:00:00 | 0:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 24:00:00 | 0:00:00 | |

SSP hydrological data : at 08:00 Hrs on 13-Nov-18

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 128.60 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 8264 Cusec 20 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 15343 Cusec 38 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 15055 | 625 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|-------|-------|------|----------|
| 628 | 0 | 17246 | 15343 | 0 | 418 |



जल संचयन - जल संरक्षण

for [Signature] 13-11-18
J.E., EMC, NCA

AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP-Asoj, Kasor, Raj-1, Raj-2 and Dhule -2 lines are in service at 10:00 hrs.

2. SSP SCO Running Details:

Unit No.2: 18:10hrs on 12.11.18 to 06:10 hrs on 13.11.18.

Unit No.3: 19:10 hrs on 12.11.18 to 05:45 hrs on 13.11.18.

Unit No.5: 19:55 hrs on 12.11.18 to 05:40 hrs on 13.11.18.