



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	13-Nov-18	0:00:00	13-Nov-18	24:00:00	24:00:00	50.00	1.183	Today(i.e. 14.11.18), 3 CHPH M/cs is running at 10:00 hrs.
2	13-Nov-18	0:00:00	13-Nov-18	0:00:00	0:00:00	0.00	0.000	
3	13-Nov-18	0:00:00	13-Nov-18	24:00:00	24:00:00	51.00	1.178	
4	13-Nov-18	0:00:00	13-Nov-18	0:00:00	0:00:00	0.00	0.000	
5	13-Nov-18	0:00:00	13-Nov-18	24:00:00	24:00:00	51.00	1.176	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	13-Nov-18	0:00:00	13-Nov-18	0:00:00	0:00:00	0	0.000	Today(i.e. 14.11.18), no SSP-RBPH M/c is scheduled.
2	13-Nov-18	0:00:00	13-Nov-18	0:00:00	0:00:00	0	0.000	
3	13-Nov-18	0:00:00	13-Nov-18	0:00:00	0:00:00	0	0.000	
4	13-Nov-18	0:00:00	13-Nov-18	0:00:00	0:00:00	0	0.000	
5	13-Nov-18	0:00:00	13-Nov-18	0:00:00	0:00:00	0	0.000	
6	13-Nov-18	0:00:00	13-Nov-18	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.537	0.000	3.537
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	20.066	0.000	20.066
PREVIOUS DAY ACTUAL RUNNING HOURS	72:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 14-Nov-18

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 128.55 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 12007 Cusec 29 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 16263 Cusec 40 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17246	628

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
625	0	16984	16263	0	417



जल संचयन - जल संवर्धन

(Signature)
14/11/18
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP-Asoj, Kasor, Raj-1, Raj-2 and Dhule -2 lines are in service at 10:00 hrs.

2. 400kV SSP-Dhule 1 is under L/C to carry out signature test.

3. SSP SCO Running Details:

Unit No.2: 18:40hrs on 13.11.18 to 07:15 hrs on 14.11.18.

Unit No.3: 19:45 hrs on 13.11.18 to 05:50 hrs on 14.11.18.

Unit No.6: 10:55 hrs on 13.11.18 to 05:45 hrs on 14.11.18.