



**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	16-Nov-18	0:00:00	16-Nov-18	24:00:00	24:00:00	50.00	1.189	Today(i.e. 17.11.18), 3 CHPH M/cs are running at 10:00 hrs.
2	16-Nov-18	0:00:00	16-Nov-18	24:00:00	24:00:00	51.00	1.209	
3	16-Nov-18	0:00:00	16-Nov-18	24:00:00	24:00:00	50.00	1.184	
4	16-Nov-18	17:30:00	16-Nov-18	22:00:00	4:30:00	50.00	0.215	
5	16-Nov-18	0:00:00	16-Nov-18	0:00:00	0:00:00	0.00	0.000	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	16-Nov-18	0:00:00	16-Nov-18	0:00:00	0:00:00	0	0.000	Today(i.e. 17.11.18), no SSP-RBPH M/c is scheduled.
2	16-Nov-18	0:00:00	16-Nov-18	0:00:00	0:00:00	0	0.000	
3	16-Nov-18	0:00:00	16-Nov-18	0:00:00	0:00:00	0	0.000	
4	16-Nov-18	0:00:00	16-Nov-18	0:00:00	0:00:00	0	0.000	
5	16-Nov-18	0:00:00	16-Nov-18	0:00:00	0:00:00	0	0.000	
6	16-Nov-18	0:00:00	16-Nov-18	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.797	0.000	3.797
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	31.413	0.000	31.413
PREVIOUS DAY ACTUAL RUNNING HOURS	76:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 16-Nov-18

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 128.06 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 35 Cusec 0.086 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 17422 Cusec 43 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
18645	628

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
625	0	18572	17422	0	409



जल संचयन - जल संरक्षण

*For Archita Karungo*  
17.11.18

AEE (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member (Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG. CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP-Asoj, Kasor, Raj-1, Raj-2 and Dhule -1 lines are in service at 10:00 hrs.

2. 400kV SSP-Dhule 2 is out to carry out Signature Test.

2. SSP SCO Running Details:

Unit No.5: 17:50hrs on 16.11.18 to 06:35hrs on 17.11.18.

Unit No.2: 21:20 hrs on 16.11.18 to 06:30 hrs on 17.11.18.