



(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|----------|----------|----------|----------|-------------|----------------|-------------------|--|
| 1 | 2-Nov-18 | 0:00:00 | 2-Nov-18 | 20:30:00 | 20:30:00 | 48.00 | 0.968 | Today(i.e. 03.11.18), 1 CHPH M/cs is running at 10:00 hrs. |
| 2 | 2-Nov-18 | 0:00:00 | 2-Nov-18 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 3 | 2-Nov-18 | 0:00:00 | 2-Nov-18 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 4 | 2-Nov-18 | 0:00:00 | 2-Nov-18 | 24:00:00 | 24:00:00 | 50.00 | 1.159 | |
| 5 | 2-Nov-18 | 12:00:00 | 2-Nov-18 | 24:00:00 | 12:00:00 | 46.00 | 0.528 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|----------|---------|----------|---------|-------------|----------------|-------------------|---|
| 1 | 2-Nov-18 | 0:00:00 | 2-Nov-18 | 0:00:00 | 0:00:00 | 0 | 0.000 | Today(i.e. 03.11.18), no SSP-RBPH M/c is scheduled. |
| 2 | 2-Nov-18 | 0:00:00 | 2-Nov-18 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 3 | 2-Nov-18 | 0:00:00 | 2-Nov-18 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 4 | 2-Nov-18 | 0:00:00 | 2-Nov-18 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 5 | 2-Nov-18 | 0:00:00 | 2-Nov-18 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 6 | 2-Nov-18 | 0:00:00 | 2-Nov-18 | 0:00:00 | 0:00:00 | 0 | 0.000 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs) | 2.655 | 0.000 | 2.655 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs) | 5.421 | 0.000 | 5.421 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 56:30:00 | 0:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 27:30:00 | 0:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 48:00:00 | 0:00:00 | |

SSP hydrological data : at 08:00 Hrs on 3-Nov-18

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 127.89 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 34150 Cusec 84 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 11265 Cusec 28 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 12037 | 632 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|-------|-------|------|----------|
| 601 | 0 | 11435 | 11265 | 0 | 403 |



जल संचयन - जल संयंत्र

for *[Signature]*
23/11/18

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP-Asoj, Kasor, Raj-1, Raj-2, Dhule-1 and Dhule -2 lines are in service at 10:00 hrs .

2. SSP SCO Running Details:

Unit No.2: 20:25 hrs on 02.11.18 to 07:35 hrs on 03.11.18.

Unit No. 6: 20:40 hrs on 02.11.18 to 7:40 hrs on 03.11.18.

AEE (EMC)
NCA, INDORE