

**DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES**  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 08-Nov-18  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 07-Nov-18

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	7-Nov-18	7:00:00	7-Nov-18	21:00:00	14:00:00	49.00	0.639	Today(i.e. 08.11.18), 1 CHPH M/cs is synchronized at 10:00 hrs.
2	7-Nov-18	0:00:00	7-Nov-18	0:00:00	0:00:00	0.00	0.000	
3	7-Nov-18	0:00:00	7-Nov-18	0:00:00	0:00:00	0.00	0.000	
4	7-Nov-18	0:00:00	7-Nov-18	0:00:00	0:00:00	0.00	0.000	
5	7-Nov-18	0:00:00	7-Nov-18	0:00:00	0:00:00	0.00	0.000	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	7-Nov-18	0:00:00	7-Nov-18	0:00:00	0:00:00	0	0.000	Today(i.e. 08.11.18), no SSP-RBPH M/c is scheduled.
2	7-Nov-18	0:00:00	7-Nov-18	0:00:00	0:00:00	0	0.000	
3	7-Nov-18	0:00:00	7-Nov-18	0:00:00	0:00:00	0	0.000	
4	7-Nov-18	0:00:00	7-Nov-18	0:00:00	0:00:00	0	0.000	
5	7-Nov-18	0:00:00	7-Nov-18	0:00:00	0:00:00	0	0.000	
6	7-Nov-18	0:00:00	7-Nov-18	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.639	0.000	0.639
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	9.781	0.000	9.781
PREVIOUS DAY ACTUAL RUNNING HOURS	14:00:00	0:00:00	
TODAY's DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 8-Nov-18

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 128.79 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 5968 Cusec 15 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2750 Cusec 7 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
2680	635

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
630	0	1774	2750	0	420



जल नियंत्रण - जल संयम

*For Archita Kamra*  
8.11.18  
AEE (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

**1. 400 kV SSP-Asoj, Kasor, Raj-2, and Dhule -2 lines are in service at 10:00 hrs.**

**2. SSP SCO Running Details:**

**Unit No.2: 9:10 hrs on 07.11.18 to 09:55 hrs on 08.11.18.**

**Unit No.3: 9:15 hrs on 07.11.18 to 08:15 hrs on 08.11.18.**

**Unit No.6: 20:20 hrs on 07.11.18 to 06:20 hrs on 08.11.18.**

**Unit No.5: 20:40 hrs on 07.11.18 to 06:25 hrs on 08.11.18.**