



**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	11-Nov-19	0:00:00	11-Nov-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 12.11.2019), 2 CHPH M/cs are running at 10:00 hrs.
2	11-Nov-19	0:00:00	11-Nov-19	0:00:00	0:00:00	0.00	0.000	
3	11-Nov-19	0:00:00	11-Nov-19	0:00:00	0:00:00	0.00	0.000	
4	11-Nov-19	10:00:00	11-Nov-19	24:00:00	14:00:00	51.00	0.699	
5	11-Nov-19	0:00:00	11-Nov-19	20:00:00	20:00:00	52.00	0.998	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	11-Nov-19	00:00:00	11-Nov-19	0:00:00	0:00:00	0	0.000	Today(i.e. 12.11.2019), 2 SSP-RBPH M/cs are running at 10:00 hrs.
2	11-Nov-19	0:00:00	11-Nov-19	0:00:00	0:00:00	0	0.000	
3	11-Nov-19	0:00:00	11-Nov-19	0:00:00	0:00:00	0	0.000	
4	11-Nov-19	0:00:00	11-Nov-19	23:00:00	23:00:00	204	4.682	
5	11-Nov-19	10:00:00	11-Nov-19	24:00:00	14:00:00	203	2.838	
6	11-Nov-19	15:00:00	11-Nov-19	24:00:00	9:00:00	203	1.812	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.697	9.332	11.029
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	26.426	85.894	112.320
PREVIOUS DAY ACTUAL RUNNING HOURS	34:00:00	46:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	39:00:00	48:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	48:00:00	

SSP hydrological data : at 08:00 Hrs on 12-Nov-19

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 138.51 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 11939 Cusec 29 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 20470 Cusec 50 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
5454	561

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
238	0	6078	6101	14369	684



जल संपन - जल संयम

*for Tauseef Ali*  
12/11/19  
AEE (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor ,Dhule-1, Dhule-2 and Raj-1 lines are in service.

2. SCO Mode Running Detail:

Unit No.1: 01:55 hrs on 12.11.2019 to 07:00 hrs on 12.11.2019

Unit No.2: 02:00 hrs on 12.11.2019 to 07:05 hrs on 12.11.2019