



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 15-Nov-19
ISSUE TIME: 10:30 Hrs
FOR DATE: 14-Nov-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	14-Nov-19	0:00:00	14-Nov-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 15.11.2019), 1 CHPH M/cs are running at 10:30 hrs.
2	14-Nov-19	0:00:00	14-Nov-19	0:00:00	0:00:00	0.00	0.000	
3	14-Nov-19	0:00:00	14-Nov-19	24:00:00	24:00:00	51.00	1.193	
4	14-Nov-19	0:00:00	14-Nov-19	0:00:00	0:00:00	0.00	0.000	
5	14-Nov-19	0:00:00	14-Nov-19	24:00:00	24:00:00	52.00	1.192	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	14-Nov-19	00:00:00	14-Nov-19	0:00:00	0:00:00	0	0.000	Today(i.e. 15.11.2019), 2 SSP-RBPH M/cs are running at 10:00 hrs.
2	14-Nov-19	0:00:00	14-Nov-19	0:00:00	0:00:00	0	0.000	
3	14-Nov-19	0:00:00	14-Nov-19	0:00:00	0:00:00	0	0.000	
4	14-Nov-19	0:00:00	14-Nov-19	0:00:00	0:00:00	0	0.000	
5	14-Nov-19	0:00:00	14-Nov-19	24:00:00	24:00:00	204	4.894	
6	14-Nov-19	0:00:00	14-Nov-19	24:00:00	24:00:00	206	4.876	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.385	9.770	12.155
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	32.589	115.174	147.763
PREVIOUS DAY ACTUAL RUNNING HOURS	48:00:00	48:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	48:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	24:00:00	

SSP hydrological data : at 08:00 Hrs on 15-Nov-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.45 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 14139 Cusec 35 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 20041 Cusec 49 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
7465	501

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
556	0	7492	7186	12855	681



Handwritten signature and date: 15/11/19, 508 MCA.

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.
2. SCO Mode Running Detail: NIL

AEE (EMC)
NCA, INDORE