



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 19-Nov-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 18-Nov-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	18-Nov-19	0:00:00	18-Nov-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 19.11.2019), 2 SSP CHPH M/cs are running at 10:00 hrs.
2	18-Nov-19	0:00:00	18-Nov-19	0:00:00	0:00:00	0.00	0.000	
3	18-Nov-19	0:00:00	18-Nov-19	0:00:00	0:00:00	0.00	0.000	
4	18-Nov-19	0:00:00	18-Nov-19	24:00:00	24:00:00	51.00	1.206	
5	18-Nov-19	0:00 18:00	18-Nov-19	11:00 24:00	17:00:00	51.00	0.838	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	18-Nov-19	00:00:00	18-Nov-19	0:00:00	0:00:00	0	0.000	Today(i.e. 19.11.2019), 3 SSP-RBPH M/cs are running at 10:00 hrs.
2	18-Nov-19	6:15:00	18-Nov-19	24:00:00	17:45:00	205	3.600	
3	18-Nov-19	6:30:00	18-Nov-19	10:00:00	3:30:00	203	0.706	
4	18-Nov-19	0:00:00	18-Nov-19	0:00:00	0:00:00	0	0.000	
5	18-Nov-19	6:00:00	18-Nov-19	12:00:00	6:00:00	204	1.230	
6	18-Nov-19	0:00 5:45	18-Nov-19	1:30 24:00	19:45:00	204	4.006	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	2.044	9.542	11.586
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	40.585	148.388	188.973
PREVIOUS DAY ACTUAL RUNNING HOURS	41:00:00	47:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	51:00:00	48:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	48:00:00	

SSP hydrological data : at 08:00 Hrs on 19-Nov-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.04 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6656 Cusec 16 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 20477 Cusec 50 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
7499	534

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
576	0	7851	7727	12750	659



जल
नियंत्रण प्राधिकरण
जल संचालन - जल संयंत्र

(Signature)
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-2 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.1: 22:05 hrs on 18.11.2019 to 05:40 hrs on 19.11.2019

Unit No.6: 01:50 hrs on 19.11.2019 to 05:45 hrs on 19.11.2019