



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 30-Nov-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 29-Nov-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	29-Nov-19	1:00 17:15	29-Nov-19	14:30 24:00	20:15:00	17.00	0.289	Today(i.e. 30.11.2019), 5 SSP CHPH M/cs are running at 10:00 hrs.
2	29-Nov-19	11:30:00	29-Nov-19	14:30:00	3:00:00	14.00	0.041	
3	29-Nov-19	0:00 17:00	29-Nov-19	15:00 24:00	22:00:00	50.00	1.092	
4	29-Nov-19	0:00:00	29-Nov-19	24:00:00	24:00:00	51.00	1.210	
5	29-Nov-19	0:00:00	29-Nov-19	24:00:00	24:00:00	51.00	1.198	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	29-Nov-19	06:30 15:30	29-Nov-19	11:40 18:45	8:25:00	203	1.710	Today(i.e. 30.11.2019), 4 SSP-RBPH M/cs are running at 10:00 hrs.
2	29-Nov-19	0:00:00	29-Nov-19	0:00:00	0:00:00	0	0.000	
3	29-Nov-19	11:40:00	29-Nov-19	12:59:00	1:19:00	205	0.070	
4	29-Nov-19	6:15 14:30	29-Nov-19	10:30 18:30	8:15:00	205	1.686	
5	29-Nov-19	6:00 14:15 21:15	29-Nov-19	10:00 18:15 24:00	10:45:00	203	2.194	
6	29-Nov-19	0:00 5:45 13:08	29-Nov-19	2:00 12:00 24:00	19:07:00	204	3.882	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.830	9.542	13.372
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	77.579	247.190	324.769
PREVIOUS DAY ACTUAL RUNNING HOURS	93:15:00	47:51:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	48:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	48:30:00	

SSP hydrological data : at 08:00 Hrs on 30-Nov-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 137.47 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 13701 Cusec 34 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 26972 Cusec 66 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
14246	521

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
602	0	15485	14031	12941	668



जल बचत - जल संयम

P. Tor
Archita Kamnig
JE (Elect)
EMC, NCA

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1,Dhule-2 and Raj-1 lines are in service.

2. SCO Mode Running Detail:

Unit No.1: 20:10hrs on 29.11.2019 to 06:10 hrs on 30.11.2019.

Unit No.2: 20:00hrs on 29.11.2019 to 06:15 hrs on 30.11.2019.