



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 09-Nov-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 08-Nov-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	8-Nov-19	0:00:00	8-Nov-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 09.11.2019), 1 CHPH M/c is running at 10:00 hrs.
2	8-Nov-19	0:00:00	8-Nov-19	0:00:00	0:00:00	0.00	0.000	
3	8-Nov-19	00:00:00 12:15:00	8-Nov-19	1:00:00 24:00:00	12:45:00	50.00	0.624	
4	8-Nov-19	0:00:00	8-Nov-19	0:00:00	0:00:00	0.00	0.000	
5	8-Nov-19	0:00:00	8-Nov-19	24:00:00	24:00:00	50.00	1.189	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	8-Nov-19	00:00:00	8-Nov-19	0:00:00	0:00:00	0	0.000	Today(i.e. 09.11.2019), 1 SSP-RBPH M/cs is running at 10:00 hrs.
2	8-Nov-19	0:00:00	8-Nov-19	0:00:00	0:00:00	0	0.000	
3	8-Nov-19	0:00:00	8-Nov-19	0:00:00	0:00:00	0	0.000	
4	8-Nov-19	0:00:00	8-Nov-19	24:00:00	24:00:00	205	4.908	
5	8-Nov-19	0:00:00	8-Nov-19	0:00:00	0:00:00	0	0.000	
6	8-Nov-19	0:00:00	8-Nov-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.813	4.908	6.721
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	21.764	66.786	88.550
PREVIOUS DAY ACTUAL RUNNING HOURS	36:45:00	24:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	24:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	24:00:00	

SSP hydrological data : at 08:00 Hrs on 9-Nov-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.49 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 14805 Cusec 36 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 12807 Cusec 31 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
6981	522

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
502	0	6516	6380	6427	681



for Ascheta Karungo
9.11.19
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.1: 20:20 hrs on 08.11.2019 to 07:40 hrs on 09.11.2019

Unit No.5: 21:00 hrs on 08.11.2019 to 07:35 hrs on 09.11.2019