

**DAILY PLANT REPORT(DPR) OF Sardar Sarovar Project Power Houses**  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 11-Nov-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 10-Nov-20

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	10-Nov-20	0:00:00	10-Nov-20	0:00:00	0:00:00	0.00	0.000	Today (i.e. 11.11.2020), 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	10-Nov-20	0:00:00	10-Nov-20	24:00:00	24:00:00	51.00	1.201	
3	10-Nov-20	0:00:00	10-Nov-20	0:00:00	0:00:00	0.00	0.000	
4	10-Nov-20	0:00:00	10-Nov-20	24:00:00	24:00:00	51.00	1.211	
5	10-Nov-20	0:00:00	10-Nov-20	24:00:00	24:00:00	51.00	1.196	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	10-Nov-20	0:00:00	10-Nov-20	0:00:00	0:00:00	0	0.000	Today(i.e. 11.11.2020), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	10-Nov-20	0:00:00	10-Nov-20	0:00:00	0:00:00	0	0.000	
3	10-Nov-20	0:00:00	10-Nov-20	0:00:00	0:00:00	0	0.000	
4	10-Nov-20	0:00:00	10-Nov-20	0:00:00	0:00:00	0	0.000	
5	10-Nov-20	0:00:00	10-Nov-20	0:00:00	0:00:00	0	0.000	
6	10-Nov-20	0:00:00	10-Nov-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.608	0.000	3.608
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	31.486	0.000	31.486
PREVIOUS DAY ACTUAL RUNNING HOURS	72:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	62:30:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 11-Nov-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 135.05 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 13638 Cusec 33.37 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 13071 Cusec 31.98 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
12570	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
572	0	12803	13071	0	567



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.1: 19:35 hrs on 10.11.2020 to 07:35 Hrs on 11.11.2020.

Unit No.6: 19:20 hrs on 10.11.2020 to 07:30 Hrs on 11.11.2020.

AEE (EMC)  
NCA, INDORE

*Handwritten signature and date: 11/11/2020*  
AEE (EMC)