



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 12-Nov-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 11-Nov-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	11-Nov-20	0:00:00	11-Nov-20	0:00:00	0:00:00	0.00	0.000	Today (i.e. 12.11.2020), 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	11-Nov-20	0:00:00	11-Nov-20	24:00:00	24:00:00	50.00	1.205	
3	11-Nov-20	0:00:00	11-Nov-20	0:00:00	0:00:00	0.00	0.000	
4	11-Nov-20	0:00:00	11-Nov-20	24:00:00	24:00:00	52.00	1.210	
5	11-Nov-20	00:00 11:30	11-Nov-20	2:00 24:00	14:30:00	50.00	0.714	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	11-Nov-20	0:00:00	11-Nov-20	0:00:00	0:00:00	0	0.000	Today (i.e. 12.11.2020), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	11-Nov-20	0:00:00	11-Nov-20	0:00:00	0:00:00	0	0.000	
3	11-Nov-20	0:00:00	11-Nov-20	0:00:00	0:00:00	0	0.000	
4	11-Nov-20	0:00:00	11-Nov-20	0:00:00	0:00:00	0	0.000	
5	11-Nov-20	0:00:00	11-Nov-20	0:00:00	0:00:00	0	0.000	
6	11-Nov-20	0:00:00	11-Nov-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.129	0.000	3.129
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	34.615	0.000	34.615
PREVIOUS DAY ACTUAL RUNNING HOURS	62:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 12-Nov-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.95 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 1169 Cusec 2.86 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 13275 Cusec 32.48 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
12803	572

- AVERAGE OUTFLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
605	0	12901	13275	0	565



for Shewank
12/11/20
JE/EM/NCA
AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG. CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.1: 19:35 hrs on 11.11.2020 to 06:15 Hrs on 12.11.2020.

Unit No.6: 19:25 hrs on 11.11.2020 to 06:10 Hrs on 12.11.2020.