



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 13-Nov-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 12-Nov-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	12-Nov-20	17:30:00	12-Nov-20	24:00:00	6:30:00	50.00	0.328	Today (i.e. 13.11.2020), 2 SSP-CHPH M/c are running at 10:00 hrs.
2	12-Nov-20	0:00:00	12-Nov-20	15:33:00	15:33:00	50.00	0.780	
3	12-Nov-20	0:00:00	12-Nov-20	0:00:00	0:00:00	0.00	0.000	
4	12-Nov-20	0:00:00	12-Nov-20	24:00:00	24:00:00	51.00	1.206	
5	12-Nov-20	00:00 15:45	12-Nov-20	10:00 24:00	18:15:00	51.00	0.902	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	12-Nov-20	0:00:00	12-Nov-20	0:00:00	0:00:00	0	0.000	Today (i.e. 13.11.2020), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	12-Nov-20	0:00:00	12-Nov-20	0:00:00	0:00:00	0	0.000	
3	12-Nov-20	0:00:00	12-Nov-20	0:00:00	0:00:00	0	0.000	
4	12-Nov-20	0:00:00	12-Nov-20	0:00:00	0:00:00	0	0.000	
5	12-Nov-20	0:00:00	12-Nov-20	0:00:00	0:00:00	0	0.000	
6	12-Nov-20	0:00:00	12-Nov-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.216	0.000	3.216
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	37.831	0.000	37.831
PREVIOUS DAY ACTUAL RUNNING HOURS	64:18:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 13-Nov-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.95 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 13126 Cusec 32.11 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 12562 Cusec 30.73 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
12901	605

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
573	0	12667	12562	0	564



for Shubh  
13/11/20  
J.P. EMC, NCA

AEE (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.3.: 18:15 hrs on 12.11.2020 to 06:10 Hrs on 13.11.2020.

Unit No.4: 18:20 hrs on 12.11.2020 to 06:15 Hrs on 13.11.2020.