

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 14-Nov-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 13-Nov-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	13-Nov-20	0:00:00	13-Nov-20	24:00:00	24:00:00	50.00	1.186	Today (i.e. 14.11.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs. SSP CHPH unit No.2 under L/C due to noise and vibrations.
2	13-Nov-20	0:00:00	13-Nov-20	0:00:00	0:00:00	0.00	0.000	
3	13-Nov-20	0:00:00	13-Nov-20	0:00:00	0:00:00	0.00	0.000	
4	13-Nov-20	0:00:17:30	13-Nov-20	9:30:24:00	16:00:00	51.00	0.795	
5	13-Nov-20	0:00:00	13-Nov-20	24:00:00	24:00:00	51.00	1.193	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	13-Nov-20	0:00:00	13-Nov-20	0:00:00	0:00:00	0	0.000	Today(i.e. 14.11.2020), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	13-Nov-20	0:00:00	13-Nov-20	0:00:00	0:00:00	0	0.000	
3	13-Nov-20	0:00:00	13-Nov-20	0:00:00	0:00:00	0	0.000	
4	13-Nov-20	0:00:00	13-Nov-20	0:00:00	0:00:00	0	0.000	
5	13-Nov-20	0:00:00	13-Nov-20	0:00:00	0:00:00	0	0.000	
6	13-Nov-20	0:00:00	13-Nov-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.174	0.000	3.174
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	41.005	0.000	41.005
PREVIOUS DAY ACTUAL RUNNING HOURS	64:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 14-Nov-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.98 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 17018 Cusec 41.64 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 12652 Cusec 30.95 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
12666	573

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
574	0	12404	12652	0	564



Copy to :


- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

- Unit No.2.: 17:50 hrs on 13.11.2020 to 06:10 Hrs on 14.11.2020.
- Unit No.5.: 18:00 hrs on 13.11.2020 to 06:15 Hrs on 14.11.2020
- Unit No.1.: 20:00 hrs on 13.11.2020 to 06:45 Hrs on 14.11.2020
- Unit No.6.: 20:10 hrs on 13.11.2020 to 06:50 Hrs on 14.11.2020


 (AEE (EMC)
 NCA, INDORE
 JE(EMC)
 NCA.