



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 17-Nov-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 16-Nov-20

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN Mus | REMARKS |
|----------|-----------|----------------|-----------|----------------|-------------|----------------|-------------------|---|
| 1 | 16-Nov-20 | 0:00:00 | 16-Nov-20 | 24:00:00 | 24:00:00 | 51.00 | 1.198 | Today (i.e. 17.11.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs. SSP CHPH unit No.2 under L/C due to noise and vibrations. |
| 2 | 16-Nov-20 | 0:00:00 | 16-Nov-20 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 3 | 16-Nov-20 | 0:00:00 | 16-Nov-20 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 4 | 16-Nov-20 | 0:00:00 | 16-Nov-20 | 24:00:00 | 24:00:00 | 51.00 | 1.210 | |
| 5 | 16-Nov-20 | 00:00 23:00 | 16-Nov-20 | 11:00 24:00 | 12:00:00 | 50.00 | 0.593 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN Mus | REMARKS |
|----------|-----------|---------|-----------|---------|-------------|----------------|-------------------|--|
| 1 | 16-Nov-20 | 0:00:00 | 16-Nov-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | Today (i.e. 17.11.2020), 0 SSP-RBPH M/c is running at 10:00 hrs. |
| 2 | 16-Nov-20 | 0:00:00 | 16-Nov-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 3 | 16-Nov-20 | 0:00:00 | 16-Nov-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 4 | 16-Nov-20 | 0:00:00 | 16-Nov-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 5 | 16-Nov-20 | 0:00:00 | 16-Nov-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 6 | 16-Nov-20 | 0:00:00 | 16-Nov-20 | 0:00:00 | 0:00:00 | 0 | 0.000 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs) | 3.001 | 0.000 | 3.001 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs) | 50.262 | 0.000 | 50.262 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 60:00:00 | 0:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 72:00:00 | 0:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 72:00:00 | 0:00:00 | |

SSP hydrological data : at 08:00 Hrs on 17-Nov-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.98 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 12450 Cusec 30.46 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 11885 Cusec 29.08 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 12007 | 559 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|-------|-------|------|----------|
| 577 | 0 | 12097 | 11885 | 0 | 565 |



जल संचालन - जल संचालन

(Signature)
AEE (EMC)
NCA, INDORE
17/11/2020

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, & Raj-1 lines are in service.

2. SCO Mode Running Details:

Unit No.1: 18:10 Hrs on 16.11.2020 to 05:45 Hrs on 17.11.2020.

Unit No.6: 18:20 Hrs on 16.11.2020 to 05:50 Hrs on 17.11.2020.