



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF Sardar Sarovar Project Power Houses
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 02-Nov-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 01-Nov-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	1-Nov-20	0:00:00	1-Nov-20	24:00:00	24:00:00	50.00	1.198	Today (i.e. 02.11.2020), 2 SSP-CHPH M/c is running at 10:00 hrs.
2	1-Nov-20	0:00:00	1-Nov-20	0:00:00	0:00:00	0.00	0.000	
3	1-Nov-20	0:00:00	1-Nov-20	0:00:00	0:00:00	0.00	0.000	
4	1-Nov-20	0:00:00	1-Nov-20	24:00:00	24:00:00	51.00	1.224	
5	1-Nov-20	11:00:00	1-Nov-20	24:00:00	13:00:00	50.00	0.641	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	1-Nov-20	0:00:00	1-Nov-20	0:00:00	0:00:00	0	0.000	Today(i.e. 02.11.2020), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	1-Nov-20	0:00:00	1-Nov-20	0:00:00	0:00:00	0	0.000	
3	1-Nov-20	0:00:00	1-Nov-20	0:00:00	0:00:00	0	0.000	
4	1-Nov-20	0:00:00	1-Nov-20	0:00:00	0:00:00	0	0.000	
5	1-Nov-20	0:00:00	1-Nov-20	0:00:00	0:00:00	0	0.000	
6	1-Nov-20	0:00:00	1-Nov-20	0:00:00	0:00:00	0	0.000	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		3.063	0.000	3.063
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		3.063	0.000	3.063
PREVIOUS DAY ACTUAL RUNNING HOURS		61:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 2-Nov-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 135.65 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 15545 Cusec 38.03 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 12428 Cusec 30.41 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
10613	620

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	11928	12428	0	584



जल सफल - जल सेवक

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasore, Dhule-2,Dhulue-1 Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.1: 19:55 hrs on 01.11.2020 to 06:30 Hrs on 02.11.2020.

Unit No.6: 20:05 hrs on 01.11.2020 to 06:35 Hrs on 02.11.2020.

AEE (EMC)
NCA, INDORE