

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	25-Nov-20	0:00:00	25-Nov-20	24:00:00	24:00:00	50.00	1.200	Today (i.e. 26.11.2020), 4 SSP-CHPH M/c's are running at 10:00 hrs. Unit No. 3 under L/C
2	25-Nov-20	00:00 14:00	25-Nov-20	12:00 24:00	22:00:00	51.00	1.109	
3	25-Nov-20	0:00:00	25-Nov-20	0:00:00	0:00:00	0.00	0.000	
4	25-Nov-20	00:00 13:45	25-Nov-20	12:00 24:00	22:15:00	51.00	1.119	
5	25-Nov-20	0:00:00	25-Nov-20	24:00:00	24:00:00	51.00	1.191	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	25-Nov-20	0:00:00	25-Nov-20	0:00:00	0:00:00	0	0.000	Today(i.e. 26.11.2020), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	25-Nov-20	0:00:00	25-Nov-20	0:00:00	0:00:00	0	0.000	
3	25-Nov-20	0:00:00	25-Nov-20	0:00:00	0:00:00	0	0.000	
4	25-Nov-20	0:00:00	25-Nov-20	0:00:00	0:00:00	0	0.000	
5	25-Nov-20	0:00:00	25-Nov-20	0:00:00	0:00:00	0	0.000	
6	25-Nov-20	0:00:00	25-Nov-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.619	0.000	4.619
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	87.814	0.000	87.814
PREVIOUS DAY ACTUAL RUNNING HOURS	92:15:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 26-Nov-20

DATA RECEIVED FROM FLOOD CELL

RESERVOIR LEVEL IN Metres	134.68 Mtrs.	
AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs).	13643 Cusec	33.38 MCM
AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs).	18159 Cusec	44.43 MCM
GOG WATER REQUIREMENT(Next Day) in Cusec		

HR	GODBOLE
18621	616

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
616	0	19033	18159	0	557



[Signature]
26/11/2020
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
 - GoMP. Member(Power), NVDA, Bhopal
 - GoMah. CE, WRD, Mumbai
 - GoG CE(E&M), SSNNL, Vadoadra
- NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 & Raj-2 lines are in service.
2. SCO Mode Running Details:
Unit No.6: 18:35 Hrs on 25.11.2020 to 06:45 Hrs on 26.11.2020.
Unit No.5: 18:45 Hrs on 25.11.2020 to 06:40 Hrs on 26.11.2020.
Unit No.1: 02:30 Hrs on 26.11.2020 to 05:35 Hrs on 26.11.2020.
Unit No.3: 02:40 Hrs on 26.11.2020 to 06:40Hrs on 26.11.2020.