



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 27-Nov-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 26-Nov-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	26-Nov-20	0:00:00	26-Nov-20	24:00:00	24:00:00	51.00	1.199 ✓	Today (i.e. 27.11.2020), 4 SSP-CHPH M/cs are running at 10:00 hrs. Unit No. 3 under L/C
2	26-Nov-20	00:00 15:30	26-Nov-20	12:00 24:00	20:30:00	50.00	1.027 ✓	
3	26-Nov-20	0:00:00	26-Nov-20	0:00:00	0:00:00	0.00	0.000	
4	26-Nov-20	00:00 15:15	26-Nov-20	12:00 24:00	20:45:00	52.00	1.050 ✓	
5	26-Nov-20	0:00:00	26-Nov-20	24:00:00	24:00:00	52.00	1.198 ✓	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	26-Nov-20	0:00:00	26-Nov-20	0:00:00	0:00:00	0	0.000	Today(i.e. 27.11.2020), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	26-Nov-20	0:00:00	26-Nov-20	0:00:00	0:00:00	0	0.000	
3	26-Nov-20	0:00:00	26-Nov-20	0:00:00	0:00:00	0	0.000	
4	26-Nov-20	0:00:00	26-Nov-20	0:00:00	0:00:00	0	0.000	
5	26-Nov-20	0:00:00	26-Nov-20	0:00:00	0:00:00	0	0.000	
6	26-Nov-20	0:00:00	26-Nov-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.474 ✓	0.000	4.474
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	92.288 ✓	0.000	92.288
PREVIOUS DAY ACTUAL RUNNING HOURS	89:15:00 ✓	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00 ✓	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00 ✓	0:00:00	

SSP hydrological data : at 08:00 Hrs on 27-Nov-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.68 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 18175 Cusec 44.47 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 17619 Cusec 43.11 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
19032	616

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
614	0	18207	17619	0	556



जल संचयन - जल संरक्षण

AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.6: 19:25 Hrs on 26.11.2020 to 06:00 Hrs on 27.11.2020.

Unit No.1: 19:20 Hrs on 26.11.2020 to 05:55Hrs on 27.11.2020.

[Signature]
27/11/2020