



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 29-Nov-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 28-Nov-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	28-Nov-20	0:00:00	28-Nov-20	24:00:00	24:00:00	51.00	1.209	Today (i.e. 29.11.2020), 4 SSP-CHPH M/cs are running at 10:00 hrs.  Unit No. 3 under L/C from 23.11.2020
2	28-Nov-20	00:00 16:00	28-Nov-20	13:15 24:00	21:15:00	50.00	1.056	
3	28-Nov-20	0:00:00	28-Nov-20	0:00:00	0:00:00	0.00	0.000	
4	28-Nov-20	00:00 15:45	28-Nov-20	13:15 24:00	21:30:00	51.00	1.083	
5	28-Nov-20	0:00:00	28-Nov-20	24:00:00	24:00:00	51.00	1.200	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	28-Nov-20	0:00:00	28-Nov-20	0:00:00	0:00:00	0	0.000	Today(i.e. 29.11.2020), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	28-Nov-20	0:00:00	28-Nov-20	0:00:00	0:00:00	0	0.000	
3	28-Nov-20	0:00:00	28-Nov-20	0:00:00	0:00:00	0	0.000	
4	28-Nov-20	0:00:00	28-Nov-20	0:00:00	0:00:00	0	0.000	
5	28-Nov-20	0:00:00	28-Nov-20	0:00:00	0:00:00	0	0.000	
6	28-Nov-20	0:00:00	28-Nov-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.548	0.000	4.548
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	101.660	0.000	101.660
PREVIOUS DAY ACTUAL RUNNING HOURS	90:45:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 29-Nov-20

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 134.58 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 14708 Cusec 35.98 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 17955 Cusec 43.93 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
19512	614

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
612	0	18658	17955	0	553



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.6: 19:30 Hrs on 28.11.2020 to 06:30 Hrs on 29.11.2020.

Unit No.1: 19:40 Hrs on 28.11.2020 to 06:35Hrs on 29.11.2020

AEE (EMC)  
NCA, INDORE

*Handwritten signature and date: 29/11/20*