

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 05-Nov-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 04-Nov-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Nov-20	0:00:00	4-Nov-20	24:00:00	24:00:00	51.00	1.198	Today (i.e. 05.11.2020), 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	4-Nov-20	12:00:00	4-Nov-20	24:00:00	12:00:00	50.00	0.598	
3	4-Nov-20	0:00:00	4-Nov-20	0:00:00	0:00:00	0.00	0.000	
4	4-Nov-20	0:00:00	4-Nov-20	24:00:00	24:00:00	53.00	1.223	
5	4-Nov-20	0:00:00	4-Nov-20	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Nov-20	0:00:00	4-Nov-20	0:00:00	0:00:00	0	0.000	Today(i.e. 05.11.2020), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	4-Nov-20	0:00:00	4-Nov-20	0:00:00	0:00:00	0	0.000	
3	4-Nov-20	0:00:00	4-Nov-20	0:00:00	0:00:00	0	0.000	
4	4-Nov-20	0:00:00	4-Nov-20	0:00:00	0:00:00	0	0.000	
5	4-Nov-20	0:00:00	4-Nov-20	0:00:00	0:00:00	0	0.000	
6	4-Nov-20	0:00:00	4-Nov-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	3.019	0.000	3.019
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	12.067	0.000	12.067
PREVIOUS DAY ACTUAL RUNNING HOURS	60:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	55:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 5-Nov-20

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 135.50 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6063 Cusec 14.83 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 13084 Cusec 32.01 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
11464	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
560	0	11241	13084	0	581



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.3: 20:00 hrs on 04.11.2020 to 05:55 Hrs on 05.11.2020.

Unit No.6: 20:10 hrs on 04.11.2020 to 06:00 Hrs on 05.11.2020

AEE (EMC)
NCA, INDORE

Rajesh V
05/11/20