



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 07-Nov-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 06-Nov-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	6-Nov-20	0:00:00	6-Nov-20	0:00:00	0:00:00	0.00	0.000	Today (i.e. 07.11.2020), 3 SSP-CHPH M/c's are running at 10:00 hrs.
2	6-Nov-20	0:00:00	6-Nov-20	24:00:00	24:00:00	51.00	1.202	
3	6-Nov-20	0:00:00	6-Nov-20	0:00:00	0:00:00	0.00	0.000	
4	6-Nov-20	0:00:00	6-Nov-20	24:00:00	24:00:00	51.00	1.217	
5	6-Nov-20	1:00:00	6-Nov-20	24:00:00	23:00:00	51.00	1.144	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	6-Nov-20	0:00:00	6-Nov-20	0:00:00	0:00:00	0	0.000	Today(i.e. 07.11.2020), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	6-Nov-20	0:00:00	6-Nov-20	0:00:00	0:00:00	0	0.000	
3	6-Nov-20	0:00:00	6-Nov-20	0:00:00	0:00:00	0	0.000	
4	6-Nov-20	0:00:00	6-Nov-20	0:00:00	0:00:00	0	0.000	
5	6-Nov-20	0:00:00	6-Nov-20	0:00:00	0:00:00	0	0.000	
6	6-Nov-20	0:00:00	6-Nov-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.563	0.000	3.563
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	18.400	0.000	18.400
PREVIOUS DAY ACTUAL RUNNING HOURS	71:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 7-Nov-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 135.33 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 1767 Cusec 4.32 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 12594 Cusec 30.81 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
11539	575

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
574	0	12454	12594	0	576



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.6: 20:20 hrs on 06.11.2020 to 06:50 Hrs on 07.11.2020.

Unit No.3: 20:30 hrs on 06.11.2020 to 06:45 Hrs on 07.11.2020.

AEE (EMC)
NCA, INDORE

Handwritten signature and date: 07/11/20