



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 11-Oct-19

ISSUE TIME: 10:00 Hrs

FOR DATE: 10-Oct-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-Oct-19	0:00:00	10-Oct-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 11.10.2019), 2CHPH M/c is running at 10:00 hrs.
2	10-Oct-19	0:00:00	10-Oct-19	0:00:00	0:00:00	0.00	0.000	
3	10-Oct-19	00:00 19:00	10-Oct-19	08:00 24:00	13:00:00	50.00	0.644	
4	10-Oct-19	5:00:00	10-Oct-19	24:00:00	19:00:00	52.00	0.951	
5	10-Oct-19	0:00:00	10-Oct-19	9:00:00	9:00:00	51.00	0.451	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-Oct-19	00:00:00	10-Oct-19	24:00:00	24:00:00	206	4.892	Today(i.e. 11.10.2019), all six SSP-RBPH M/cs are running.
2	10-Oct-19	0:00:00	10-Oct-19	24:00:00	24:00:00	206	4.888	
3	10-Oct-19	0:00:00	10-Oct-19	24:00:00	24:00:00	207	4.860	
4	10-Oct-19	0:00:00	10-Oct-19	24:00:00	24:00:00	205	4.938	
5	10-Oct-19	0:00:00	10-Oct-19	24:00:00	24:00:00	205	4.904	
6	10-Oct-19	0:00:00	10-Oct-19	24:00:00	24:00:00	206	4.916	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	2.046	29.398	31.444
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	12.133	284.424	296.557
PREVIOUS DAY ACTUAL RUNNING HOURS	41:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	34:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 11-Oct-19

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 138.56 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 76379 Cusec 187 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 71630 Cusec 175 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
8087	476

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
533	24167	7011	7416	40047	800



जल कषत - जल संयम

(Signature)
AEE (EMC)
NCA, INDORE
11/10/19

Copy to:

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail: Nil