



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 12-Oct-19

ISSUE TIME: 10:00 Hrs

FOR DATE: 11-Oct-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	11-Oct-19	0:00:00	11-Oct-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 12.10.2019), 2CHPH M/c is running at 10:00 hrs.
2	11-Oct-19	0:00:00	11-Oct-19	0:00:00	0:00:00	0.00	0.000	
3	11-Oct-19	0:00:00	11-Oct-19	8:30:00	8:30:00	49.00	0.414	
4	11-Oct-19	0:00:00	11-Oct-19	24:00:00	24:00:00	51.00	1.197	
5	11-Oct-19	5:00:00	11-Oct-19	24:00:00	19:00:00	50.00	0.932	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	11-Oct-19	00:00:00	11-Oct-19	24:00:00	24:00:00	206	4.880	Today(i.e. 12.10.2019), all six SSP-RBPH M/cs are running.
2	11-Oct-19	0:00:00	11-Oct-19	24:00:00	24:00:00	205	4.878	
3	11-Oct-19	0:00:00	11-Oct-19	24:00:00	24:00:00	205	4.868	
4	11-Oct-19	0:00:00	11-Oct-19	24:00:00	24:00:00	206	4.932	
5	11-Oct-19	0:00:00	11-Oct-19	24:00:00	24:00:00	205	4.944	
6	11-Oct-19	0:00:00	11-Oct-19	24:00:00	24:00:00	206	4.886	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	2.543	29.388	31.931
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	14.676	313.812	328.488
PREVIOUS DAY ACTUAL RUNNING HOURS	51:30:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	34:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 12-Oct-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.41 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 38233 Cusec 94 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 57181 Cusec 140 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
8123	533

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
601	9000	8812	8699	39482	796



Amr
AEE(EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail: Nil